



1028 Market St.
Metairie, LA 70003
PHONE: (504) 305-0385
FAX: (504) 305-0558
www.dynamicconstructors.net

May 20, 2026

Chuck Dammon
Dammon Engineering, Inc.
554 Old Spanish Trail
Slidell, LA 70458

RE: St. Tammany Fire Protection District 1
Fire Station #10 – STFPD1 – FS10

RFI 05 - Broken Piling

Dear Mr. Dammon,

Piling number 139 on the attached numbered piling plan broke at 15 feet deep. We cut the piling where it broke/blew out. Please advise if another piling needs to be driven next to it. We have included two pictures of the piling.

Please advise.

Thank you,

Georgia Barrett