

DX SPLIT SYSTEM SCHEDULE

| FURNACE / AIR HANDLER | | | | | | | | | | | | | | | | CONDENSER | | | | | | | | REMARKS | |
|-----------------------|-------------------|---------|------------|------------------|---------------------|-----------------|------------|-----------------|--------|---------------------------|------------------|---------------------------|-------|----|-----|-----------|------|-----------------|---------|------------|-------|----|------|---------|------|
| TAG | AREA SERVED | MAKE | POSITION | FURNACE MODEL | EVAP. COIL MODEL | COOLING | | HEAT (NAT. GAS) | | TOTAL AIRFLOW (CFM) | O/A Air (CFM) | ESP (¹ WC) | POWER | | | | TAG | NOMINAL TONS | MAKE | MODEL | POWER | | | | |
| | | | | | | NOMINAL TONS | TMBH (MIN) | MBH | FT3/HR | | | | VAC | PH | MCA | MOP | | | | | VAC | PH | MCA | | MOP |
| AHU-1 | Multipurpose Room | Goodman | Upflow | GR9S92030 | CAPTA48 | 4 | 48.3 | 30 | 29 | 1720 | 180 | 0.5 | 120 | 1 | 7.7 | 15 | CU-1 | 4 | Goodman | GLXS16BS48 | 208 | 1 | 25.2 | | 40 |
| AHU-2 | Kitchen / Utility | Goodman | Upflow | GR9S92030 | CAPTA42 | 3-1/2 | 42.7 | 30 | 29 | 1400 | 120 | 0.5 | 120 | 1 | 7.7 | 15 | CU-2 | 3-1/2 | Goodman | GLXS16BS42 | 208 | 1 | 19 | 30 | 1, 2 |
| AHU-3 | Guest Suite | Goodman | Upflow | GR9S92030 | CAPTA30 | 2-1/2 | 30.8 | 30 | 29 | 900 | 180 | 0.5 | 120 | 1 | 7.7 | 15 | CU-3 | 2-1/2 | Goodman | GLXS16BS30 | 208 | 1 | 15 | 25 | 1, 2 |
| AHU-4 | Second Floor | Goodman | Horizontal | GD9S92030 | CHPTA30 | 2-1/2 | 29.9 | 30 | 29 | 1025 | 200 | 0.5 | 120 | 1 | 7.7 | 15 | CU-4 | 2-1/2 | Goodman | GLXS16BS30 | 208 | 1 | 15 | 25 | 1, 2 |

NOTES:

- 1 Provide galvanized emergency pan, MERV 8 filter media, time delay relay, condensate overflow switch & programmable 7/24 thermostat.
- 2 Cooling capacities to be rated in accordance with AHRI standard 210/290 for ASHRAE standard design weather conditions.